



Inspection Record Non-Ethanol Compatible Dispensing Equipment



Dispensers not manufacturer approved or UL listed as compatible for E-Blend fuel may be operated with E-Blend fuel if the owner/operator or person authorized by the owner/operator conducts a weekly visual inspection. The components below must be visually inspected for leaks or failures. Any component that leaks or does not operate as designed must be replaced with a compatible component. Record your weekly inspections on this form (electronically or handwritten). Retain inspection records for one year. The inspection records shall be kept on-site when practical and available upon request to the Tucson Fire Department for review within two working days. **If a leak is found, write LEAK in the box. For no leak, put an X in the box.**

Month _____ Year _____	Week 1	Week 2	Week 3	Week 4	Week 5
Seals/ Gaskets					
Filter					
Suction pump					
Hoses					
Breakaway					
Nozzle/ Swivel					
Dispenser sump (DRY?)					
Pipe joints					
Flex-connector					
Shear valve					
Inspector					