



# Odor Control

## Requirements for Odor Reduction

- Playrooms on Separate HVAC Systems. Each System has an Outside Air Intake Requirement
- Steril-Aire UVC Emitters Installed on each HVAC System
- HVAC System Installed with Economizers and Dehumidification
- Temp design / relative humidity requirement:
  - Playrooms/Spa
    - 75-78 Degrees in Summer
    - 68-70 Degrees in Winter
    - 30%-60% Relative Humidity
  - Rest of the Daycare:
    - 72-75 Degrees in Summer
    - 70-72 Degrees in Winter
    - 30%-60% Relative Humidity
- Walls Extend to the Deck to Avoid Smell and Sound Transfer Between Playrooms
- Rooms Cleaned Three Times per Day
- ScentAir System Installed
- HVAC Air Filters Replaced Quarterly Versus Annually

# Sound Control

## Requirements for Sound Reduction

- Special Wall Type at Demising Wall(s) that Extend to the Roof Deck
- Special Wall Type Between Playrooms and PeopleSpace that Extend to the Roof Deck
- Air Gap at the Demising Wall
- Type A: Walls for Bathrooms, Dog Food Prep Area, etc (Non-Dog Rooms)
- Type B: Walls Between the DogPlayrooms.
- Type D: Demising Walls (Adjacent/Shared wall with Neighboring Tenant(s))
- Type C: Wall Between Playroom and People Spaces (i.e. – Hallways, Restrooms, Spa/Grooming, etc) Extends to Roof Deck

