

From: Andy Vera <Andy.Vera@tucsonaz.gov>

Sent: Tuesday, March 15, 2022, 6:33 AM

To: Maria Gayosso <Maria.Gayosso@tucsonaz.gov>

Subject: RE: [EXTERNAL]RE: IID-21-02 (T21SA00546) The Bautista - IID/IPP Application

The proposed waste collection methods and calculations are acceptable.

The development package will need to identify, in detail, the four collection points (storage area's) from each of the individual trash rooms so not to conflict or obstruct travel paths (vehicular or pedestrian), and access and approach for collection vehicle. The restaurant enclosure/s must include provisions for both trash and recycle and therefore must provide detail (w/dimensions) of one double or two single enclosures to support both service types. Currently only a single enclosure appears to be presented.

Thanks again,
Andy