

Exhibit C

City of Tucson Amendments to the 2024 International Fuel Gas Code

Chapter 1 Administration. DELETE Chapter 1 with the exception of Sections 101.2.5 and 111. (Deleted sections are administered by the 2024 IBC, Chapter 1)

Section 404.17.3 Tracer. REVISE by DELETING the entire Section and REPLACE with the following: A yellow insulated copper tracer wire or other *approved* conductor, or a product specifically designed for that purpose, shall be installed adjacent to underground nonmetallic *piping*. *Access* shall be provided to the tracer wire or the tracer wire shall terminate a minimum of 12 inches above ground at each end of the nonmetallic *piping* securely attached at both ends. The tracer wire size shall be not less than 18 AWG and the insulation type shall be suitable for direct burial.