



**2" ARV DETAIL**

FOR CCP, HDPE, DIP AND PVC PIPE  
NOT TO SCALE

**\*NOTE:**

2" ARV MUST BE INSTALLED PER PLAN LOCATION.

FLANGE INSULATING KIT MUST BE TESTED TO CONFIRM ISOLATION PRIOR TO BACKFILL. INCLUDE TEST RESULTS IN FINAL CORROSION REPORT.

ALL COPPER & BRASS SHALL BE INSULATED AND WRAPPED WITH 10 MIL TAPE.

ALL AIR RELEASE VALVE INSTALLATIONS REQUIRE A TRACER WIRE PER SECTION 210 & SD-116.

\*AIR RELEASE VALVE SHALL BE LIGHTWEIGHT PER APPROVED MATERIAL LIST (APPENDIX A).

ISSUED:		<p align="center"><b>STANDARD DETAIL</b></p> <p align="center"><b>AIR RELEASE VALVE INSTALLATION 2"</b></p>		DETAIL NO.
8/06				SD-331
REVISED:		3/17		SHEET 1 OF 1