



NOTES:

1. VALVE, PIPE JOINTS, AND END CAP SHALL BE MECHANICALLY RESTRAINED IN ACCORDANCE WITH STANDARD SPECIFICATION 1406.
2. CONCRETE THRUST BLOCKS MAY BE USED IF APPROVED BY THE ENGINEER.
3. DRAIN VALVE ASSEMBLY SHALL BE INSTALLED ON 6" STUBS MORE THAN 5' IN LENGTH AND ON ALL 8" STUBS MORE THAN 10' IN LENGTH.

ISSUED:		STANDARD DETAIL		DETAIL NO.	
6/97		DRAIN VALVE ASSEMBLY		SD-400	
REVISED:					
8/09					SHEET 1 OF 1