


June 2016

To ensure your tap water is safe, clean and secure, Tucson Water conducts approximately 14,500 individual tests each year on the water in the main distribution system – before it reaches your home. Test results for key parameters are reported by 10 water quality zones for a water distribution system that covers some 375 square miles.

Main Water System



To ensure your tap water is safe, clean and secure, Tucson Water conducts approximately 14,500 individual tests each year on the water in the main distribution system – before it reaches your home. Test results for key parameters are reported by 10 water quality zones for a water distribution system that covers some 375 square miles.

Main Water System

TEST RESULTS BY WATER QUALITY ZONE

Zones	Hardness (mg/L*) 87 SP	Sodium (mg/L*) 87 SP	Nitrate-N (mg/L*) 87 SP	Fluoride (mg/L*) 87 SP	pH Level (S.U.) 249 SP	Minerals (mg/L*) 249 SP	Temperature (deg°F) 249 SP
1	183	64	1.62	0.35	7.8	437	86.3
2	244	68	0.95	0.40	7.8	497	85.0
3	244	69	1.11	0.46	7.8	486	85.5
4	209	60	0.91	0.32	7.7	421	86.7
5	210	61	1.28	0.38	7.6	438	84.9
6	188	54	1.42	0.35	7.7	387	84.5
7	198	54	1.30	0.34	7.7	384	86.4
8	219	60	1.80	0.48	7.6	446	86.8
9	249	63	2.00	0.60	7.6	461	86.3
10	223	66	1.09	0.36	7.8	446	85.9
Avg	218	62	1.35	0.41	7.7	441	85.7

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons SP = Sample Points S.U. = Standard Units

TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.

E. coli positive samples/mo.

Follow-up assessment required?




CHLORINE

EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L

Actual Average
249 samples – 0.8 mg/L




June 2016

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Catalina Water System

Catalina is a community partially served by Tucson Water. It has about 400 connections, supplying water to about 1,000 persons with water from two wells.



TEST RESULTS from 2 Sample Points (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 2 SP	Minerals (mg/L*) 2 SP	Temperature (deg°F) 2 SP
83	23	0.45	0.60	8.1	197	86.8

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and E. coli

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?




CHLORINE



Corona de Tucson Water System

Corona de Tucson is a community located near Sahuarita and Houghton Roads, with about 2,600 connections supplying about 7,300 persons with water from three wells.



TEST RESULTS from 9 Sample Points (SP)


Hardness (mg/L*) 3 SP	Sodium (mg/L*) 3 SP	Nitrate-N (mg/L*) 3 SP	Fluoride (mg/L*) 3 SP	pH Level (S.U.) 9 SP	Minerals (mg/L*) 9 SP	Temperature (deg°F) 9 SP
213	53	0.96	0.38	7.5	387	86.0

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and E. coli

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?




CHLORINE



Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Diamond Bell Water System

Diamond Bell is a community located south and east of Sasabe Road and Diamond Bell Ranch Road respectively, with about 200 connections supplying about 570 persons with water from two wells.



TEST RESULTS from 1 Sample Point (SP)


Hardness (mg/L*) 2 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
115	29	1.50	0.20	7.8	220	81.7

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI


EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?



CHLORINE

Actual Average
1 sample – 0.9 mg/L




EPA Standard
Max. 4.0 mg/L

Tucson Water target average
0.8 to 1.2 mg/L

Rancho del Sol Lindo & White Fence Farms Water System

Rancho del Sol Lindo is a community located southwest of Silverbell Road and North Trico Road. Rancho del Sol Lindo has about 1,000 connections, supplying about 2,700 persons with water from two wells.



TEST RESULTS from 3 Sample Points (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 3 SP	Minerals (mg/L*) 3 SP	Temperature (deg°F) 3 SP
119	36	2.54	0.52	7.8	257	89.5

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI


EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?



CHLORINE

Actual Average
3 samples – 0.7 mg/L




EPA Standard
Max. 4.0 mg/L

Tucson Water target average
0.8 to 1.2 mg/L

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Sierrita Foothills Water System

This is a small community by the Three Points area, with 30 connections supplying approximately 75 people from one well.



TEST RESULTS from 1 Sample Point (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
94	39	1.68	0.48	8.0	222	85.5

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and E. coli

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?




CHLORINE

EPA Standard Max. 4.0 mg/L


Tucson Water target average 0.8 to 1.2 mg/L

Actual Average 1 sample - 0.9 mg/L



Silverbell West Water System

The Silverbell West system has 83 connections serving approximately 230 people from one well.



TEST RESULTS from 1 Sample Point (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
335	93	1.95	0.45	7.5	621	87.4

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons

TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and E. coli

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?




CHLORINE

EPA Standard Max. 4.0 mg/L

Tucson Water target average 0.8 to 1.2 mg/L

Actual Average 1 sample - 0.6 mg/L




June 2016

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Thunderhead Ranch Water System

Thunderhead Ranch is a small subdivision west of Old Spanish Trail and about one and a half miles south of Irvington Road. It has about 57 connections supplying about 160 persons with water from two wells.



TEST RESULTS from 1 Sample Point (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
75	13	1.43	0.15	7.9	141	77.0

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons


TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?




CHLORINE



Tucson Police-Fire Academy Water System

The Police-Fire Academy, located south of Interstate 10 and east of Wilmot Road, was built in the late 1990s. One well supplies about 25 persons regularly, plus class members taught at this facility.



TEST RESULTS from 1 Sample Point (SP)


Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
200	40	0.80	0.28	7.6	355	76.1

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons


TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.
E. coli positive samples/mo.
Follow-up assessment required?



CHLORINE




June 2016

Tucson Water also monitors water quality at 10 separate and distinct community systems served solely by local groundwater wells – not from the main water distribution system. Hundreds of individual tests are conducted each year on these community wells to ensure well water is clean, safe and secure.

Valley View Acres Water System

Valley View Acres is a small community located north of Hilltop Road, just west of Sandario Road, with about 150 connections supplying about 470 people with water from two wells.



TEST RESULTS from 1 Sample Point (SP)

Hardness (mg/L*) 1 SP	Sodium (mg/L*) 1 SP	Nitrate-N (mg/L*) 1 SP	Fluoride (mg/L*) 1 SP	pH Level (S.U.) 1 SP	Minerals (mg/L*) 1 SP	Temperature (deg°F) 1 SP
101	50	1.58	0.43	7.5	266	84.2

*mg/L means milligrams per liter 1 mg/L = 1 teaspoon in 1,302 gallons


TOTAL COLIFORM & E. COLI

EPA standards for Total Coliform and *E. coli*

Total Coliform positive samples/mo.

E. coli positive samples/mo.


Follow-up assessment required?



CHLORINE

Actual Average

1 sample – 0.6 mg/L



EPA Standard
Max. 4.0 mg/L

Tucson Water
target average
0.8 to 1.2 mg/L